



Zone Result Summary -2009

Sample Point Code	Sample Point Description	Parameter Code	Parameter Name	Parameter Type	Limit	Qualifier	Min Result	Mean Result	Max Result	Number of Results	Number of Fails	% Compliance
ZBWH03	STANBBRIDGE SOUTH ZONE											
		A001	Colour(Hazen)	N	20		0.6	1.120	2.8	44		
		A002	Turbidity (FTU)	N	4		0.1	0.136	0.4	44		
		A003	Odour Quantitative	N	3		0	0	0	44		
		A004	Taste Quantitative	N	3		0	0	0	43		
		A006	pH (pH Units)	N	10		7.4	7.645	7.9	44		
		A007	Sulphate (mg SO4/l)	I	250		10.3	16.75	24.8	10		
		A009	Sodium Total (mg Na/l)	N	150		7.2	10.12	16	10		
		A012	Nitrate (mg NO3/l)	D	50		20.3	31.11	40.12	46		
		A013A	Nitrite (mg NO2/l)(WSZ)	D	0.5		0.01	0.047	0.28	46		
		A013C	Nitrite/Nitrate Formula	D			0.42	0.636	0.81	46		
		A014	Ammonium (mg NH4/l)	I	0.5		0.01	0.084	0.18	44		
		A017	Total Organic Carbon (mg C/l)	I			0.3	1.32	2.2	10		
		A021	Aluminium Total (ug Al/l)	N	200	<	2	2.233	3.86	8		
		A022	Iron Total (ug Fe/l)	N	200	<	9	9.338	11.7	8		
		A023	Manganese Total (ug Mn/l)	N	50	<	2	2	2	8		
		A024A	Copper Total (mg Cu/l)	D	2		0.003	0.015	0.048	10		
		A027	Fluoride (ug F/l)	D	1500		0.08	0.09	0.1	10		
		B001A	Arsenic (ug As/l)	D	10		0.3	0.466	1.1	10		
		B002	Cadmium (ug Cd/l)	D	5	<	0.4	0.4	0.4	10		
		B003	Cyanide (ug CN/l)	D	50	<	1.2	1.52	1.6	10		

Parameter Type - D=EU Directive Standard, N=National Standard, I=Indicator Parameter

Sample Point Code	Sample Point Description	Parameter Code	Parameter Name	Parameter Type	Limit	Qualifier	Min Result	Mean Result	Max Result	Number of Results	Number of Fails	% Compliance
ZBWH03	STANBBRIDGE SOUTH ZONE											
		B004	Chromium (ug Cr/l)	D	50	<	0.5	0.5	0.5	10		
		B005	Mercury (ug Hg/l)	D	1		0.02	0.045	0.26	10		
		B006A	Nickel (ug Ni/l)	D	20	<	1.5	2.863	15	10		
		B007A	Lead Total (ug Pb/l)	D	25	<	0.5	0.5	0.5	10		
		B008A	Antimony (ug Sb/l)	D	5		0.05	0.471	1.7	10		
		B009	Selenium (ug Se/l)	D	10		0.47	0.701	1.1	10		
		B010	Total Pesticides (ug/l)	D	0.5		0	0.002	0.01	10		
		B011F	PolyAromaticHydrocarbons (ug Total PAH/l)	D	0.1		0	0.0004	0.004	10		
		B11B	Benzo(b)fluoranthene (ug/l)	D		<	0.001	0.001	0.001	7		
		B11C	Benzo(k)fluoranthene (ug/l)	D		<	0.001	0.001	0.001	7		
		B11D	Benzo(ghi)perylene (ug/l)	D		<	0.001	0.002	0.002	7		
		B11E	Indeno(123-cd)pyrene (ug/l)	D		<	0.001	0.002	0.003	7		
		C001A	Total Coliforms (Ind) (No./100 ml)	I			0	0	0	112		
		C002	Faecal Coliforms (No./100 ml)	D	0		0	0	0	112		
		C003	Enterococci (No./100 ml)	D	0		0	0	0	10		
		C007	Colony Count 3 day @ 22 Deg C (no/ml)	I			0	10.43	300	44		
		C009	Chlorine Free (mg Cl2/l)				0	0.029	0.19	112		
		C010	Chlorine Total (mgCl2/l)				0.1	0.26	0.48	112		
		C013	Colony Count 2 day @ 37 Deg C (no/ml)	I			0	6.182	178	44		
		D001	Conductivity at 20C (usie/cm)	I	1500		431	540.2	2400	44		
		D002A	Chloride (mg Cl/l)	I	250		19	22.8	29	10		

Parameter Type - D=EU Directive Standard, N=National Standard, I=Indicator Parameter

<i>Sample Point Code</i>	<i>Sample Point Description</i>	<i>Parameter Code</i>	<i>Parameter Name</i>	<i>Parameter Type</i>	<i>Limit</i>	<i>Qualifier</i>	<i>Min Result</i>	<i>Mean Result</i>	<i>Max Result</i>	<i>Number of Results</i>	<i>Number of Fails</i>	<i>% Compliance</i>
ZBWH03	STANBBRIDGE SOUTH ZONE											
		D005A	Boron (mg B/l)	D	1	<	0.03	0.035	0.046	10		
		D007	Benzo(a)pyrene (ug/l)	D	0.01	<	0.001	0.001	0.001	10		
		D008	Tetrachloromethane(ug CCl4/l)	N	3	<	0.1	0.1	0.1	10		
		D009B	Tetera+Trichloroethene (ug/l)	D	10		0	0	0	10		
		D011	Trihalomethanes (ug THM/l)	D	100		0.4	12.78	31.9	10		
		D11A	Chloroform (ug/l)	D			0.2	4.386	9.7	7		
		D11B	Bromodichloromethane (ug/l)	D			0.2	5.429	11.3	7		
		D11C	Chlorodibromomethane (ug/l)	D			0.2	5.286	10.1	7		
		D11D	Bromoform (ug/l)	D		<	0.2	1.057	2.6	7		
		F001	1,2 dichloroethane	D	3	<	0.2	0.2	0.2	10		
		F002	Benzene	D	1	<	0.1	0.1	0.1	10		
		F003	Bromate (ug/l BrO3)	D	10	<	1	1.32	2.2	10		
		F004	Radioactivity (Gross Alpha) (Bq/l)	I	0.1	<	0.02	0.021	0.026	10		
		F005	Radioactivity (Gross Beta) (Bq/l)	I	1		0.06	0.068	0.101	10		
		F006	Tritium (Bq/l)	I	100	<	10	10	10	10		
		F007	Total Indicative Dose	I	0.1	<	0.1	0.1	0.1	10		
		P004	Atrazine (ug/l)	D	0.1	<	0.004	0.005	0.009	10		
		P006	Bentazone (ug/l)	D	0.1	<	0.003	0.003	0.004	10		
		P008	Bromoxynil (ug/l)	D	0.1	<	0.003	0.003	0.003	10		
		P013	Chlorfenvinphos (ug/l)	D	0.1	<	0.003	0.008	0.009	10		
		P014	Chlortoluron (ug/l)	D	0.1	<	0.004	0.004	0.004	10		

Parameter Type - D=EU Directive Standard, N=National Standard, I=Indicator Parameter

<i>Sample Point Code</i>	<i>Sample Point Description</i>	<i>Parameter Code</i>	<i>Parameter Name</i>	<i>Parameter Type</i>	<i>Limit</i>	<i>Qualifier</i>	<i>Min Result</i>	<i>Mean Result</i>	<i>Max Result</i>	<i>Number of Results</i>	<i>Number of Fails</i>	<i>% Compliance</i>
ZBWH03	STANBBRIDGE SOUTH ZONE											
		P015	Chlorothalonil (ug/l)	D	0.1	<	0.004	0.004	0.006	10		
		P017	Chlorpyriphos (ug/l)	D	0.1	<	0.003	0.004	0.004	10		
		P018	Clopyralid (ug/l)	D	0.1	<	0.002	0.005	0.006	10		
		P020	2,4-D (ug/l)	D	0.1	<	0.002	0.003	0.004	10		
		P024	Diazinon (ug/l)	D	0.1	<	0.003	0.004	0.004	10		
		P025	Dicamba (ug/l)	D	0.1	<	0.002	0.002	0.003	10		
		P026	Dichlorprop (ug/l)	D	0.1	<	0.003	0.004	0.004	10		
		P028	Dieldrin (ug/l)	D	0.1	<	0.003	0.007	0.007	10		
		P032	Diuron (ug/l)	D	0.1	<	0.004	0.004	0.006	10		
		P037	Fenpropimorph (ug/l)	D	0.1	<	0.003	0.006	0.006	10		
		P040	Fluoroxypyr (ug/l)	D	0.1	<	0.003	0.003	0.003	1		
		P041	HCH Gamma Lindane (ug/l)	D	0.1	<	0.003	0.004	0.004	10		
		P048	Isoproturon (ug/l)	D	0.1	<	0.004	0.004	0.005	10		
		P049	Ioxynil (ug/l)	D	0.1	<	0.003	0.006	0.007	10		
		P051	Linuron (ug/l)	D	0.1	<	0.005	0.005	0.007	10		
		P053	Mecoprop (ug/l)	D	0.1	<	0.002	0.002	0.003	10		
		P054	MCPA (ug/l)	D	0.1	<	0.002	0.003	0.004	10		
		P055	MCPB (ug/l)	D	0.1	<	0.002	0.003	0.003	10		
		P060	Pentachlorophenol (PCP) (ug/l)	D	0.1	<	0.003	0.003	0.003	10		
		P069	Propetamphos (ug/l)	D	0.1	<	0.004	0.004	0.004	10		
		P071	Propyzamide (ug/l)	D	0.1	<	0.003	0.003	0.004	10		

Parameter Type - D=EU Directive Standard, N=National Standard, I=Indicator Parameter

<i>Sample Point Code</i>	<i>Sample Point Description</i>	<i>Parameter Code</i>	<i>Parameter Name</i>	<i>Parameter Type</i>	<i>Limit</i>	<i>Qualifier</i>	<i>Min Result</i>	<i>Mean Result</i>	<i>Max Result</i>	<i>Number of Results</i>	<i>Number of Fails</i>	<i>% Compliance</i>
ZBWH03	STANBBRIDGE SOUTH ZONE											
		P073	Simazine (ug/l)	D	0.1	<	0.003	0.004	0.004	10		
		P079	Triallate (ug/l)	D	0.1	<	0.003	0.003	0.003	10		
		P081	Trifluralin (ug/l)	D	0.1	<	0.003	0.005	0.005	10		
		P082	2,4-DB (ug/l)	D	0.1	<	0.003	0.003	0.003	10		
		P094	Cypermethrin (ug/l)	D	0.1	<	0.005	0.013	0.014	10		
		P098	Dichlobenil (ug/l)	D	0.1	<	0.002	0.002	0.004	10		
		P118	Pendimethalin (ug/l)	D	0.1	<	0.003	0.003	0.005	10		
		P119	Permethrin (ug/l)	D	0.1	<	0.006	0.008	0.008	10		
		P122	Picloram (ug/l)	D	0.1	<	0.005	0.006	0.007	10		
		P126	Propachlor (ug/l)	D	0.1	<	0.003	0.003	0.003	1		
		P131	Triclopyr (ug/l)	D	0.1	<	0.002	0.002	0.003	10		
		P138	Benazolin (ug/l)	D	0.1	<	0.004	0.004	0.004	10		
		P150	Carbendazim (ug/l)	D	0.1	<	0.004	0.004	0.005	10		
		P157	Diflufenican (ug/l)	D	0.1	<	0.003	0.003	0.003	10		
		P159	Flusilazole (ug/l)	D	0.1	<	0.009	0.009	0.01	10		
		P177	Tebuconazole (ug/l)	D	0.1	<	0.005	0.005	0.007	10		
		P207	Cyproconazole (ug/l)	D	0.1	<	0.01	0.011	0.011	1		
		P217	Epoxiconazole (ug/l)	D	0.1	<	0.003	0.008	0.009	10		
		P218	Kresoxim-methyl (ug/l)	D	0.1	<	0.003	0.003	0.003	10		
		P227	Azoxystrobin (ug/l)	D	0.1	<	0.004	0.004	0.006	10		
		P228	Cyprodinil (ug/l)	D	0.1	<	0.003	0.003	0.003	10		

Parameter Type - D=EU Directive Standard, N=National Standard, I=Indicator Parameter

<i>Sample Point Code</i>	<i>Sample Point Description</i>	<i>Parameter Code</i>	<i>Parameter Name</i>	<i>Parameter Type</i>	<i>Limit</i>	<i>Qualifier</i>	<i>Min Result</i>	<i>Mean Result</i>	<i>Max Result</i>	<i>Number of Results</i>	<i>Number of Fails</i>	<i>% Compliance</i>
ZBWH03	STANBBRIDGE SOUTH ZONE	P229	Trifloxystrobin (ug/l)	D	0.1	<	0.004	0.004	0.006	10		

Parameter Type - D=EU Directive Standard, N=National Standard, I=Indicator Parameter

Bournemouth & West Hampshire
WATER